

# Glen Cove South Water Quality Report - 2005

**To comply with Safe Drinking Water Act amendments and the Washington State Department of Health mandates,** Jefferson County Public Utility District #1 annually issues a report on monitoring performed on each of its water systems. The purpose of this report is to advance consumer's understanding of drinking water and heighten awareness of the need to protect precious water resources. If you have any specific water system questions please feel free to contact the Glen Cove South water system manager, Doug Reeder at 385-5800 ext 305 or 301-0708 (cell). **Additionally, the PUD Board meets** on the first and third Wednesday of each month at 5:00 p.m. at the PUD office; please feel free to attend these meetings. Your district is District 2 and your commissioner is M Kelly Hayes. **The State of Washington has declared a drought twice in the last 5 years. Please conserve and use water wisely. You can find conservation tips on our web site at [jeffpud.org](http://jeffpud.org).**

**Is my water safe?** Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The PUD safeguards its water supplies and once again we are proud to report that your system water has never exceeded a maximum contaminant level.

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring mineral and, in some cases, radio-active material, and can pick up substances resulting from the presence of animals or from human activity.

**Your water comes from three municipal wells,** two are located at the south end of the Jefferson County International Airport, the third is located on N. Willison Ave. All the wells are part of a well head protection plan that restricts any activity that could contaminate them. After the water comes out of the wells, we add disinfectant to protect you against microbial contaminants. Well 2 and the Willison well (#3) are now both using a treatment facility designed to remove the secondary (aesthetic) contaminants of iron and manganese from the water. In 2004, the Tri-Area water system was interconnected to the Glen Cove South System now formally called the Quimper Water System. A new well, the Four Corners well, was drilled late in 2004 and will likely be online sometime in late 2005.

**Examples of contaminants that may affect source water** include: **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife, **Inorganic contaminants**, such as salts and metal, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic waste water discharges, oil and gas production, mining or farming, **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses, **Radioactive contaminants**, which are naturally occurring, and **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

**Do I need to take special precautions?** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

**Drinking water, including bottled water,** may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791), or Donna Freier at the State DOH (360-236-3162).

**In order to ensure that tap water is safe** to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminant in bottled water which must provide the same protection for public health.

**Regarding Arsenic detected in your water (in 2003):** While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

## Water Quality Data Table

The table below lists all the drinking water contaminants that we detected during the 2004 calendar year, unless otherwise noted. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 - December 31, 2004. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

**Terms & abbreviations used below:** **Maximum Contaminant Level Goal (MCLG):** the level of a contaminant in drinking water below which there is not known or expected risk to health. MCLGs allow for a margin of safety. **Maximum Contaminant Level (MCL):** the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. **Action Level (AL):** the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. **N/a:** not applicable; **nd:** not detectable at testing limit **ppb:** parts per billion or micrograms per liter **ppm:** parts per million or milligrams per liter **pCi/l:** picocuries per liter (a measure of radiation); **mg/L:** milligrams per liter (same as ppm)

Inorganic Contaminant	MCL	MCLG	Well#1	Well#2	Well#3	Sample Date	Violation	Typical Source
<b>EPA Regulated</b>								
Arsenic	0.05 mg/l	0				2/26/03	NO	Erosion of natural deposits; runoff from orchards, runoff from glass & electronics production wastes
			0.005 mg/l			3/5/03	NO	
<b>EPA Regulated (Secondary)</b>								
Chloride	250 mg/l				10 mg/l	1/26/04	NO	Natural deposits, seawater

---

Nitrate was tested for in wells 1 and 2 on 12/30/04 and was not detected in either well.

Note: The EPA requires monitoring of over 80 drinking water contaminants. Those listed above are not the only compounds detected in your drinking water.